

**Company:** UNICRIMP Limited  
Declares that under our sole responsibility the product(s)  
**Product Name:** Q-Fire Products & Components  
**Description:** Fire-Safe Cable Clips 25mm (120Min)  
**Product Reference(s):** QFGFC25

is/are in conformity with the provisions of the following statutory requirements, including all amendments, and with national legislation implementing these regulations:

**UK SI 2013 No. 3113** UK Packaging Waste Regulations

For the provisions of **RoHS** (Restriction of the use of Certain Hazardous Substances) and **REACH** (Registration, Evaluation, Authorisation and Restriction of Chemicals), please refer to the independent statements, see QR Codes with links below.

The following designated standards have been applied:

<b>BS 5839-1:2013 (Section 26.2e)</b>	Fire detection and fire alarm systems for buildings – Part 1: Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises
<b>BS 8434-2 :2003</b>	Methods of test for assessment of the fire integrity of electric cables-Part 2: Test for unprotected small cables for use in emergency circuits- BS EN 50200 with a 930 °C flame and with water spray
<b>BS EN 50200:2006 PH120</b>	Method of test for resistance to fire of unprotected small cables for use in emergency circuits

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001: 2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of: Unicrimp Limited.



Mark Flanagan - Head of Product Development  
Date: 02-01-2024  
Place of Issue: As Below

**Company:** UNICRIMP Limited  
Declares that under our sole responsibility the product(s)  
**Product Name:** Q-Fire Products & Components  
**Description:** Fire-Safe Cable Clips 25mm (120Min)  
**Product Reference(s):** QFGFC25

are / is in conformity with the provisions of the following EU directives and regulations, including all amendments, and with national legislation implementing these directives:

**94/62/EC** European Directive on Packaging and Packaging Waste


For the provisions of **RoHS** (Restriction of the use of Certain Hazardous Substances) and **REACH** (Registration, Evaluation, Authorisation and Restriction of Chemicals), please refer to the independent statements, see QR Codes with links below.

The following designated standards have been applied:

<b>BS 5839-1:2013 (Section 26.2e)</b>	Fire detection and fire alarm systems for buildings – Part 1: Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises
<b>BS 8434-2 :2003</b>	Methods of test for assessment of the fire integrity of electric cables-Part 2: Test for unprotected small cables for use in emergency circuits- BS EN 50200 with a 930 °C flame and with water spray
<b>BS EN 50200:2006 PH120</b>	Method of test for resistance to fire of unprotected small cables for use in emergency circuits

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001: 2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of:  
Unicrimp Limited.



Mark Flanagan – Head of Product Development  
Date: 02-01-2024  
Place of Issue: As Below