

Company: UNICRIMP Limited
Declares that under our sole responsibility the product(s)
Product Name: Q-Fire Products & Components
Description: Fire-Safe Cable Clips 50mm (120Min)
Product Reference(s): QFGFC50

is/are in conformity with the provisions of the following statutory requirements, including all amendments, and with national legislation implementing these regulations:

UK SI 2013 No. 3113 UK Packaging Waste Regulations

For the provisions of **RoHS** (Restriction of the use of Certain Hazardous Substances) and **REACH** (Registration, Evaluation, Authorisation and Restriction of Chemicals), please refer to the independent statements, see QR Codes with links below.

The following designated standards have been applied:

BS 5839-1:2013 (Section 26.2e) Fire detection and fire alarm systems for buildings – Part 1: Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises

BS 8434-2 :2003 Methods of test for assessment of the fire integrity of electric cables-Part 2: Test for unprotected small cables for use in emergency circuits- BS EN 50200 with a 930 °C flame and with water spray

BS EN 50200:2006 PH120 Method of test for resistance to fire of unprotected small cables for use in emergency circuits

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001: 2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of: Unicrimp Limited.



Mark Flanagan - Head of Product Development
Date: 02-01-2024
Place of Issue: As Below

Company: UNICRIMP Limited
Declares that under our sole responsibility the product(s)
Product Name: Q-Fire Products & Components
Description: Fire-Safe Cable Clips 50mm (120Min)
Product Reference(s): QFGFC50

are / is in conformity with the provisions of the following EU directives and regulations, including all amendments, and with national legislation implementing these directives:

94/62/EC European Directive on Packaging and Packaging Waste


For the provisions of **RoHS** (Restriction of the use of Certain Hazardous Substances) and **REACH** (Registration, Evaluation, Authorisation and Restriction of Chemicals), please refer to the independant statements, see QR Codes with links below.

The following designated standards have been applied:

BS 5839-1:2013 (Section 26.2e)	Fire detection and fire alarm systems for buildings – Part 1: Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises
BS 8434-2 :2003	Methods of test for assessment of the fire integrity of electric cables-Part 2: Test for unprotected small cables for use in emergency circuits- BS EN 50200 with a 930 °C flame and with water spray
BS EN 50200:2006 PH120	Method of test for resistance to fire of unprotected small cables for use in emergency circuits

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001: 2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of: Unicrimp Limited.



Mark Flanagan – Head of Product Development
Date: 02-01-2024
Place of Issue: As Below